




TRENCHED INSTALLATION



EMBANKMENT INSTALLATION




CULVERT AND BASE CONFIGURATION



NOTE :  
FOR H ≥ 1.5m PROVIDE HORIZONTAL PROPS AT 0.4 x HEIGHT ABOVE BASE DURING BACKFILLING AND COMPACTION. ONE PROP PER PRECAST UNIT

TEMPORARY PROPPING ARRANGEMENT



DETAIL A

CULVERT SIZE.		FOUNDATION CONDITIONS			
		1 & 2		3 & 4	
SPAN (mm)	HEIGHT (mm)	CLASS	FILL (m)	CLASS	FILL (m)
600	x 300	200 S	10.2	200 S	5.6
600	x 450		11.0		6.0
600	x 600		12.0		6.4
750	x 300	175 S	8.7	175 S	4.9
750	x 450		9.2		5.2
750	x 600		10.0		5.5
750	x 750	175 S	10.5	175 S	5.8
900	x 300		8.6		4.8
900	x 450		9.0		5.1
900	x 600	175 S	9.5	175 S	5.3
900	x 750		10.0		5.6
900	x 900		10.2		5.8
1200	x 300	150 S	7.1	150 S	4.1
1200	x 450		7.4		4.3
1200	x 600		7.7		4.4
1200	x 900	150 S	8.2	150 S	4.7
1200	x 1200		8.8		5.0
1500	x 300	100 S	4.5	100 S	2.9
1500	x 450		4.7		3.0
1500	x 600		4.9		3.1
1500	x 900	100 S	5.3	100 S	3.3
1500	x 1200		5.6		3.5
1500	x 1500		6.0		3.7
1800	x 600	75 S	3.3	75 S	2.4
1800	x 900		3.6		2.5
1800	x 1200		3.8		2.7
1800	x 1500	75 S	4.0	75 S	2.8
1800	x 1800		4.3		2.9
2100	x 600	75 S	3.3	75 S	2.4
2100	x 900		3.5		2.6
2100	x 1200		3.7		2.7
2100	x 1500	75 S	3.9	75 S	2.8
2100	x 1800		4.1		2.9
2100	x 2100		4.3		3.0
2400	x 600	75 S	3.2	75 S	2.4
2400	x 900		3.4		2.5
2400	x 1200		3.5		2.6
2400	x 1500	75 S	3.7	75 S	2.9
2400	x 1800		3.8		2.8
2400	x 2400		4.0		3.0
3000	x 600	75 S	3.1	75 S	2.4
3000	x 900		3.2		2.5
3000	x 1200		3.3		2.6
3000	x 1500	75 S	3.4	75 S	2.7
3000	x 1800		3.5		2.7
3000	x 2400		3.7		2.9
3000	x 3000	75 S	3.1	75 S	2.7
3600	x 600		3.1		2.4
3600	x 900		3.1		2.5
3600	x 1200	75 S	3.2	75 S	2.6
3600	x 1500		3.3		2.6
3600	x 1800		3.3		2.7
3600	x 2400	75 S	3.5	75 S	2.8
3600	x 3000		3.5		2.7

TABLE 1. Maximum fill height on S-load culverts under SNABC traffic loading

REFERENCE DRAWINGS

THIS DRAWING FORMS PART OF AND MUST BE READ IN CONJUNCTION WITH TYPICAL DRAWINGS TD-S-C-001 & TD-S-C-002

NOTES  
PERMISSIBLE FILL HEIGHTS  
THE RELATIONSHIP BETWEEN THE S-LOAD CULVERT CLASSES DEFINED IN SANS 986 AND THE CORRESPONDING MAXIMUM PERMISSIBLE FILL HEIGHTS TO MEET THE TMH7 REQUIREMENT WAS CALCULATED AND IS GIVEN IN TABLE 1. IF CULVERTS ARE TO BE PLACED UNDER HIGHER FILLS THAN THOSE GIVEN IN THIS TABLE THEN A HIGHER S-LOAD CLASS MUST BE SPECIFIED.

DEFINITIONS  
YIELDING FOUNDATION CONDITIONS OCCUR WHEN THE FOUNDING MATERIAL AND THE FILL MATERIAL ARE EXPECTED TO SETTLE AT EQUAL RATES (COMPRESSIBLE MATERIAL). THE LOADING IS CALCULATED IN ACCORDANCE WITH TMH7 PART 2 CLAUSE 2.3.3.2(2).

UNYIELDING FOUNDATION CONDITIONS OCCUR WHEN THE FOUNDATION MATERIAL IS INCOMPRESSIBLE (SOFT ROCK OR OTHER HARDER MATERIAL). THE LOADING IS CALCULATED IN ACCORDANCE WITH TMH7 PART 2 CLAUSE 2.3.3.2(3) AND (4).

TRENCH CONDITION OCCURS WHEN CULVERTS ARE LAID IN A NARROW EXCAVATION AND BACKFILLED TO GROUND LEVEL

EMBANKMENT (UNTRENCHED) CONDITION OCCURS WHEN CULVERTS ARE LAID AT GROUND LEVEL AND BACKFILLED TO FINAL FORMATION LEVEL

THE COMBINATIONS OF FOUNDATION AND INSTALLATION CONDITIONS USED IN TMH7 ARE DEFINED AS:  
CONDITION 1: CULVERTS IN TRENCH IN UNYIELDING FOUNDATION WITH NO PROJECTION.  
CONDITION 2: CULVERTS UNTRENCHED ON YIELDING FOUNDATION.  
CONDITION 3: CULVERTS UNTRENCHED ON UNYIELDING FOUNDATION FOR h > 1.7b  
CONDITION 4: CULVERTS UNTRENCHED ON UNYIELDING FOUNDATION FOR h ≤ 1.7b

WHERE h = FILL HEIGHT IN METRES (ABOVE UNIT)  
b = OVERALL TRENCH WIDTH OR, IF UNTRENCHED, OVERALL CULVERT WIDTH, IN METRES.

ASSUMPTIONS  
THE FOLLOWING ASSUMPTIONS AND CLAUSES OF TMH7 PART 1 AND 2 WERE USED TO COMPILE TABLE 1

- A MINIMUM FILL HEIGHT OF 300mm OVER THE CULVERT UNITS. WHERE THIS CANNOT BE ACHIEVED A 100mm REINFORCED CONCRETE SLAB MUST BE USED.
- STANDARD TRAFFIC LOADING (SNABC) AS DESCRIBED IN CLAUSE 2.6.1.2.
- FILL MATERIAL UNIT WEIGHT 20kN/m³ [CLAUSE 2.3.1]
- CONCRETE UNIT WEIGHT 24kN/m³ [CLAUSE 2.2.1]
- HORIZONTAL EARTH PRESSURE 7.8kN/m² PER METRE DEPTH [CLAUSE 2.4.2]
- ULTIMATE LIMIT STATE LOAD FACTORS TABLE 7.